

Siltuma zudumu aprēķins															
Telpa			Atdzisusi virsma								Papildinājumi				Siltuma zudumi, W
Telpa nr.	Nosaukums	Temperatūra telpā, °C	Nosaukums	Orientācija	L, m	H, m	Daudzums	S, m²	Siltumatdeves koef., U W/(m²·°C)	Temperatūras starpība, °C	Debess puses, %	Vējš, %	Citi, %	Papildinājuma koeficients	
1	2		3	4	5	6	7	8	9	10	11	12	13	14	15
2.Stāvs															
Nr.3															
1	Dzīvojamā istaba	20	AS	A	5,48	3,80	1	20,82	0,95	43	10%	5%	0%	1,15	985
		22	AS	Z	6,13	3,80	1	23,29	0,95	45	10%	5%	0%	1,15	1153
		20	L	Z	1,00	1,60	2	3,20	1,55	43	10%	5%	0%	1,15	494
		20	J	-			1	24,59	1,03	43	0%	0%	0%	1,00	1097
		20	INF	-	24,59	3,60	1,0	88,52	0,12	43	0%	0%	0%	1,00	460
														Kopā	4189
2	Istaba	20	AS	A	5,95	3,80	1	22,61	0,95	43	10%	5%	0%	1,15	1070
		20	AS	D	3,10	3,80	1	11,78	0,95	43	0%	5%	0%	1,05	509
		20	L	D	1,00	1,60	1	1,60	1,55	43	0%	5%	0%	1,05	113
		20	J	-			1	11,64	1,03	43	0%	0%	0%	1,00	519
		20	INF	-	11,64	3,60	1,0	41,90	0,12	43	0%	0%	0%	1,00	218
														Kopā	2428
3	Virtuve ar istabu	18	AS	D	6,50	3,80	1	24,70	0,95	41	0%	5%	0%	1,05	1018
		18	L	D	1,00	1,60	2	3,20	1,55	41	0%	5%	0%	1,05	430
		18	L	D	1,00	2,00	1	2,00	1,55	41	0%	5%	0%	1,05	134
		18	IS	-	5,00	3,60	1	18,00	1,05	2	0%	0%	0%	1,00	38
		18	D	-	0,80	2,00	1	1,60	1,35	2	0%	0%	0%	1,00	4
		18	J	-			1	30,31	1,03	41	0%	0%	0%	1,00	1289
		18	INF	-	30,31	3,60	1,0	109,12	0,12	41	0%	0%	0%	1,00	541
														Kopā	3454
4	Sanmezgls	25	IS	-	2,51	3,60	2	18,07	1,05	7	0%	0%	0%	1,00	266
		25	J	-			1	2,50	1,03	48	0%	0%	0%	1,00	124
		25	INF	-	2,50	3,60	2,0	18,00	0,12	48	0%	0%	0%	1,00	209
														Kopā	599
5	Tualete	18	IS	-	1,00	3,65	1	3,65	1,05	2	0%	0%	0%	1,00	8
		18	IS	-	1,00	3,65	1	3,65	1,05	2	0%	0%	0%	1,00	8
		18	J	-			1	0,93	1,03	41	0%	0%	0%	1,00	40
		18	INF	-	0,93	3,10	2,0	5,77	0,12	41	0%	0%	0%	1,00	57
														Kopā	112
6	Istaba	18	AS	Z	5,05	3,80	1	19,19	0,95	41	10%	5%	0%	1,15	866
		18	L	Z	1,00	1,60	1	1,60	1,55	41	10%	5%	0%	1,15	118
		18	IS	-	4,63	3,60	1	16,67	1,05	2	0%	0%	0%	1,00	35
		18	J	-			1	13,77	1,03	41	0%	0%	0%	1,00	586
		18	INF	-	13,77	3,60	1,0	49,57	0,12	41	0%	0%	0%	1,00	246
														Kopā	1850
Kopā dzīvoklis															12632
Nr.4															
1	Istaba	20	AS	A	5,85	3,80	1	22,23	0,95	43	10%	5%	0%	1,15	1052
		22	AS	D	3,09	3,80	1	11,74	0,95	45	0%	5%	0%	1,05	531
		20	L	D	1,00	1,60	1	1,60	1,55	43	0%	5%	0%	1,05	113
		20	J	-			1	11,86	1,03	43	0%	0%	0%	1,00	529
		20	INF	-	11,86	3,60	1,0	42,70	0,12	43	0%	0%	0%	1,00	222
														Kopā	2446
2	Dzīvojamā istaba	18	AS	D	4,03	3,80	1	15,31	0,95	41	0%	5%	0%	1,05	631
		18	L	D	1,00	1,60	1	1,60	1,55	41	0%	5%	0%	1,05	108
		18	L	D	1,00	2,00	1	2,00	1,55	41	0%	5%	0%	1,05	134
		18	J	-			1	19,06	1,03	41	0%	0%	0%	1,00	811
		18	INF	-	19,06	3,60	1,0	68,62	0,12	41	0%	0%	0%	1,00	340
														Kopā	2024

V.Kazačonoks 3-01532				OBJEKTS: Apkures sistēmas rekonstrukcijas projekts DAUGAVPILS, RAIŅA IELĀ 23				Pasūtījuma Nr. TP_08/22	
AMATS	V.UZVĀRDS	PARAKSTS	DATUMS	PASŪTĪTĀJS: SIA "DDzKSU"				Stadija	Lapa
								T.p.	2/4
Inžen.	V.Kazačonoks		05.2022.g	LAPAS NOSAUKUMS:				Mērogs	Marka
Izstr.	S.Zaharovs		05.2022.g	Siltuma zudumu aprēķins				b/m	AVK